


	<b>CONFINED SPACE HAZARD ASSESSMENT</b>		HA # 9
	<b>CONFINED SPACE NAME:</b> Boilers	<b>ID #</b> Boiler1/ Boiler 2	<b>LOCATION:</b> Gerry Brewer Building

<b>Confined Space?</b>	<b>YES</b>	
YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> Enclosed or partially enclosed?		
YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> Limited or restricted entry/exit?		
YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> Intended for continuous human occupancy?		
YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> Large enough that a worker can enter?		

<b>SPACE INFORMATION/DETAILS (IN OPERATION):</b>																							
<b>SPACE DESCRIPTION:</b> Two identical gas and oil fed hot-water boilers found in the Gerry Brewer Building. The boilers are five-pass steel boilers with flexible watertubes formed and arranged so as to direct the flow of combustible gases through the boiler. The pressure vessel consists of formed tubes, the external downcomer and the top and bottom drums to which they connect. The heated area of the pressure vessel is contained within a gas tight insulate casing that is comprised of refractory bricks and removable formed steel panels.																							
<b>CONTENTS:</b> Watertubes, pressure vessel (external downcomer and the top and bottom drums) and refractory brick <i>Equipment:</i> Burner at one end (fireside), electrical panel/devices																							
<b>PROCESS/FUNCTION/USE DESCRIPTION:</b> For heating the Gerry Brewer Building using a hot water system.																							
<b>PHYSICAL CHARACTERISTICS:</b> Two horizontal rectangular shaped vessels – identical in size <b>DIMENSIONS:</b> Approximately (feet - 'ft'): 4 ft (W) x 6 ft (L) x 6 ft (H) <b>VOLUME:</b> 144 ft <sup>3</sup> <b>SPACE MATERIAL:</b> Carbon steel with refractory brick lining and high temperature insulation																							
<b>ENTRY CHARACTERISTICS:</b> <b>LOCATIONS:</b> Side entry – behind burner <b>SIZE:</b> 2 ft x 2 ft <b>SECURING MECHANISM:</b> Bolted hatch style door																							
<b>ADJACENT VESSELS/SPACES/PIPING:</b> <table border="1" style="width: 100%;"> <thead> <tr> <th><u>NAME OF SPACE/PIPE</u></th> <th><u>CONTENTS</u></th> <th><u>TEMPERATURE</u></th> <th><u>PRESSURE</u></th> </tr> </thead> <tbody> <tr> <td>Inlets (0.5" – 2" Ø)</td> <td>Natural gas and oil (separate feeds)</td> <td>No concern</td> <td>4-5 psi</td> </tr> <tr> <td>Inlet (1" Ø)</td> <td>Water</td> <td>No concern</td> <td>No concern</td> </tr> <tr> <td>Vent/relief valve (2" Ø)</td> <td>Air/flue gas</td> <td>No concern</td> <td>No concern</td> </tr> <tr> <td>Outlet (2" Ø)</td> <td>Hot water</td> <td>150°F - 240°F</td> <td>160 psi</td> </tr> </tbody> </table>				<u>NAME OF SPACE/PIPE</u>	<u>CONTENTS</u>	<u>TEMPERATURE</u>	<u>PRESSURE</u>	Inlets (0.5" – 2" Ø)	Natural gas and oil (separate feeds)	No concern	4-5 psi	Inlet (1" Ø)	Water	No concern	No concern	Vent/relief valve (2" Ø)	Air/flue gas	No concern	No concern	Outlet (2" Ø)	Hot water	150°F - 240°F	160 psi
<u>NAME OF SPACE/PIPE</u>	<u>CONTENTS</u>	<u>TEMPERATURE</u>	<u>PRESSURE</u>																				
Inlets (0.5" – 2" Ø)	Natural gas and oil (separate feeds)	No concern	4-5 psi																				
Inlet (1" Ø)	Water	No concern	No concern																				
Vent/relief valve (2" Ø)	Air/flue gas	No concern	No concern																				
Outlet (2" Ø)	Hot water	150°F - 240°F	160 psi																				

<b>SCOPE OF WORK:</b>
This Hazard Assessment (HA) refers to entry for the purpose of inspection (with flashlight), cleaning and refractory brick repair. Cleaning involves manually removing debris (soot/dust/fibres) on steel surfaces (fire side surfaces) with a wire brush and manually removing dust/fibres on refractory bricks with a HEPA filter vacuum. Refractory brick repair includes manual patchwork to cracks with a mouldable product (Inswool Moldable and Inswool-HP Blanket 8).

<b>HAZARDOUS ATMOSPHERIC RATING (LOW, MOD. HIGH)</b>	<b>Moderate</b>	<b>JUSTIFICATION:</b> Potential for dust (including refractory ceramic fibres and silica) to exceed the applicable exposure limits.
<b>COMPLETED BY:</b>	<b>Prepared by:</b> Peter Bergholz, BSc, CIH, AMEC, November 2012 <b>Reviewed by:</b> Victor Leung, MSc, CIH, ROH, CRSP, AMEC, November 2012	<b>INFO. SOURCE:</b> Paul Elsoff & Richard Howard

	<b>CONFINED SPACE HAZARD ASSESSMENT</b>		HA # 9
	<b>CONFINED SPACE NAME:</b> Boilers	<b>ID #</b> Boiler1/ Boiler 2	<b>LOCATION:</b> Gerry Brewer Building

Hot work and other atmospheric contaminant generating activities (e.g., high pressure water washing, painting) are not included in this Hazard Assessment.

HAZARDS		UNDISTURBED SPACE POTENTIAL HAZARDS	WORK TASKS POTENTIAL HAZARDS	CONTROL MEASURES
ATMOSPHERE	Oxygen (O <sub>2</sub> ) Deficiency	Yes If shut down for a period of time	No	Monitoring for O <sub>2</sub> . Continuous negative air ventilation with HEPA filter during entry. Place negative air ventilation with HEPA filter inside vent, relief valve or waterside inspection covers.
	O <sub>2</sub> Enrichment	No	No	
	Chemical	Yes Natural gas/oil is used for fuel. Soot /light corrosion residue may be present on steel surfaces.	Yes <b>Steel &amp; Refractory Brick Cleaning:</b> Dust containing soot, light corrosion residue, silica and refractory ceramic fibres present.  <b>Refractory Brick Repair:</b> Silica and refractory ceramic fibres present – MSDS reviewed for Inswool Moldable and Inswool-HP Blanket 8.	Monitoring for CO. Continuous negative air ventilation with HEPA filter during entry. Ensure natural gas/oil line is isolated and locked out prior to entry  <b>General PPE:</b> Full-face respirator with P100 cartridges, disposable Tyvek coveralls, safety boots, work gloves (disposable nitrile), hard hat and hearing protection.  Use HEPA filter vacuum cleaner for dust/fibre/soot cleaning and decontamination of PPE and equipment after exiting space.  Mouldable product is a mat-like material and not dusty during application.  <b>Note:</b> respirator requirements are recommended in the absence of space-specific exposure monitoring data.
	Biological	No	No	
	Fire/Explosion	Yes Natural gas/oil is used for fuel.	No	Monitoring for LEL. Continuous negative air ventilation with HEPA filter during entry. Ensure natural gas/oil line is isolated and locked out prior to entry
SAFETY	Structural Hazard	No	No	
	Engulfment	No	No	
	Entrapment	No	No	
	Electrical	Yes Electrical panel/devices present as per boiler manual	No	Boiler must be isolated and locked out prior to entry.

<b>HAZARDOUS ATMOSPHERIC RATING (LOW, MOD. HIGH)</b>	<b>Moderate</b>		<b>JUSTIFICATION:</b> Potential for dust (including refractory ceramic fibres and silica) to exceed the applicable exposure limits.
<b>COMPLETED BY:</b>	<b>Prepared by:</b> Peter Bergholz, BSc, CIH, AMEC, November 2012 <b>Reviewed by:</b> Victor Leung, MSc, CIH, ROH, CRSP, AMEC, November 2012	<b>INFO. SOURCE:</b> Paul Elsoff & Richard Howard	

This Hazard Assessment (HA) pertains to the activity and confined space listed above. This hazard assessment is required to be reviewed within 3 years of preparation; any change in activity requires a review of this HA and a completion of a HA for the specific activity (especially when contaminants will be generated by an activity such as welding, radiation or chemical usage).

	<b>CONFINED SPACE HAZARD ASSESSMENT</b>		HA # 9
	<b>CONFINED SPACE NAME:</b> Boilers	<b>ID #</b> Boiler1/ Boiler 2	<b>LOCATION:</b> Gerry Brewer Building

HAZARDS		UNDISTURBED SPACE POTENTIAL HAZARDS	WORK TASKS POTENTIAL HAZARDS	CONTROL MEASURES
	Access/Egress	<b>Yes</b> Entry door is behind burner.	No	Burner is required to be removed. Work with care as crawling is required.
	Fall	No	No	
	Slip/Trip	No	No	
	Visibility/Light Level	<b>Yes</b> Insufficient lighting	No	Flashlight only required.
	Baffles/Internal Arrangement	<b>Yes</b> Watertubes present throughout space and in the floor	No	Wood platform is required on the floor surface for crawling inside.
	Floor Openings in Space	No	No	
PHYSICAL	Noise/Vibration	No	<b>Yes</b> HEPA filter vacuum can be loud inside the boiler	Hearing protection required (wear <b>General PPE</b> ).
	Temperature	<b>Yes</b> Boiler is hot	No	Cool for a sufficient time period and drain (watertubes) prior to entry.
	Non/Ionizing Radiation	No	No	
	Laser	No	No	
OTHERS	Ingestion/Skin Contact Hazard	No	<b>Yes</b> Potential for skin/eye irritation - MSDS reviewed for Inswool Moldable and Inswool-HP Blanket 8	Wear <b>General PPE</b>
	Mechanical Hazard	No	No	
	Traffic Hazard	No	No	
	Hydraulic/Pneumatic Hazard	No	No	

CONTROL MEASURES REQUIRED:	
<b>Confined Space Permit:</b>	Yes
<b>Atmospheric Testing:</b>	Gas monitor with sensors for O <sub>2</sub> , LEL, CO & H <sub>2</sub> S.
<b>Ventilation Requirements:</b>	Provide continuous negative air ventilation with HEPA filter during the entire entry. Minimum ventilation requirements are based on achieving 20 air changes per hour. Place negative air ventilation with HEPA filter inside vent, relief valve or waterside inspection covers.
<b>PPE Requirements:</b>	<b>General PPE:</b> Full-face respirator with P100 cartridges, disposable Tyvek coveralls, safety boots, work gloves (disposable nitrile), hard hat and hearing protection. Use HEPA filter vacuum cleaner for dust/fibre/soot cleaning and decontamination of PPE and equipment after exiting space. <b>Note:</b> respirator requirements are recommended in the absence of space-specific exposure monitoring data.
<b>Lockout/Isolation:</b>	Boiler must be isolated and locked out prior to entry. Ensure natural gas/oil line is isolated and locked out prior to entry.
<b>Standby Person:</b>	Yes, at or near entrance.

<b>HAZARDOUS ATMOSPHERIC RATING (LOW, MOD. HIGH)</b>	<b>Moderate</b>		<b>JUSTIFICATION:</b> Potential for dust (including refractory ceramic fibres and silica) to exceed the applicable exposure limits.
	<b>COMPLETED BY:</b> Prepared by: Peter Bergholz, BSc, CIH, AMEC, November 2012 Reviewed by: Victor Leung, MSc, CIH, ROH, CRSP, AMEC, November 2012	<b>INFO. SOURCE:</b> Paul Elsoff & Richard Howard	

This Hazard Assessment (HA) pertains to the activity and confined space listed above. This hazard assessment is required to be reviewed within 3 years of preparation; any change in activity requires a review of this HA and a completion of a HA for the specific activity (especially when contaminants will be generated by an activity such as welding, radiation or chemical usage).

	<b>CONFINED SPACE HAZARD ASSESSMENT</b>		HA # 9
	<b>CONFINED SPACE NAME:</b> Boilers	<b>ID #</b> Boiler1/ Boiler 2	<b>LOCATION:</b> Gerry Brewer Building

CONTROL MEASURES REQUIRED:	
<b>Communication Procedures:</b>	Radio (no cellular telephone), voice
<b>Rescue Procedures:</b>	Standby person calls 911 and calls Entry Supervisor. Entry Supervisor will respond to scene. Self rescue (if possible) or manual removal.
<b>Required Rescue and Safety Equipment</b>	Two-way radio
<b>Other:</b>	Mouldable product is a mat-like material and not dusty during application. Burner is required to be removed. Work with care as crawling is required. Flashlight only required. Wood platform is required on the floor surface for crawling inside. Cool for a sufficient time period and drain (watertubes) prior to entry.

<b>HAZARDOUS ATMOSPHERIC RATING (LOW, MOD. HIGH)</b>	<h2>Moderate</h2>	<b>JUSTIFICATION:</b> Potential for dust (including refractory ceramic fibres and silica) to exceed the applicable exposure limits.
<b>COMPLETED BY:</b>	<b>Prepared by:</b> Peter Bergholz, BSc, CIH, AMEC, November 2012 <b>Reviewed by:</b> Victor Leung, MSc, CIH, ROH, CRSP, AMEC, November 2012	<b>INFO. SOURCE:</b> Paul Elsoff & Richard Howard

This Hazard Assessment (HA) pertains to the activity and confined space listed above. This hazard assessment is required to be reviewed within 3 years of preparation; any change in activity requires a review of this HA and a completion of a HA for the specific activity (especially when contaminants will be generated by an activity such as welding, radiation or chemical usage).